

Inspection and maintenance of RPZ backflow preventer, type BA acc. EN 806-5

TO BE COMPLETED ONLY AFTER PRIOR STUDY OF THE INSTALLATION AND OPERATING INSTRUCTIONS!



Backflow preventer	
Systemtrenner BA	
Figure-No.	

Year 1		Year 2		Year 3	
Inspection	Maintenance	Inspection	Maintenance	Inspection	Maintenance
Date:	Date:	Date:	Date:	Date:	Date:
Company:	Company:	Company:	Company:	Company:	Company:
Inspector:	Inspector:	Inspector:	Inspector:	Inspector:	Inspector:

Inspection

// Access safety valve
// Visual inspection for leakage at the stop valve and strainer connections
// Check free drain
// Check if water is in the odor trap

Maintenance

// Clean strainer
// Static pressure / dynamic pressure / differential pressure
// Function test of inlet check valve
// Function test of discharge valve
// Function test of outlet check valve

/	/	mbar	/	/	mbar

Note	Note	Note	Note	Note	Note